

		PRESSURE TRANSMITTER - ADL10					SHEET: 1 of 2	
		REVISION	BY	CHECK	APPROVED	DATE	ALTUS N°:	
							CUSTOMER	
							CUSTOMER N°:	
DESCRIPTION				TAG NUMBER:			MODEL:	ADL10 - HX-XXXXXXXX-XX-XXXX
OUTPUT / PROTOCOL		H	4 - 20 mA / Hart 7				OBSERVATION	
SENSOR	POSITION	A	HIGH PRESSURE			☐		
		B	LOW PRESSURE			☐		
	TYPE	A	ABSOLUTE			☐		
		M	MANOMETRIC			☐		
	RANGE	1	-7,5 a 7,5 kPa (-765 a 765 mm H2O)			☐		
		2	-37,4 a 37,4 kPa (-3814 a 3814 mm H2O)			☐		
		3	-147,1 a 147,1 kPa (-1,5 a 1,5 kgf/cm²)			☐		
		4	-690 a 690 kPa (-7 a 7 kgf/cm²)			☐		
5		-2068 a 2068 kPa (-21 a 21 kgf/cm²)			☐			
DIAPHRAGM MATERIAL		I	STAINLESS STEEL 316L			☐		
		H	HASTELLOY C276			☐		
		Z	SPECIAL			☐		
FILLING FLUID		S	SILICONE OIL			☐		
		N	NEOBEE M20			☐		
		Z	SPECIAL			☐		
FLANGE/ADAPTER/PURGE MATERIAL		I	STAINLESS STEEL 316			☐		
		Z	SPECIAL			☐		
PURGE POSITION		0	WITHOUT PURGE			☐		
		1	OPPOSITE SIDE TO PROCESS CONNECTION			☐		
		2	UPPER			☐		
		3	LOW			☐		
CELL SEALING RING		B	BUNA-N			☐		
		V	VITON			☐		
		T	TEFLON			☐		
PROCESS CONECTION		0	1/4" - 18NPT FEMALE			☐		
		1	1/2" - 14NPT (WITHOUT ADAPTER)			☐		
		2	FLAGE 1 1/2" X 150# NO EXTENSION			☐		
		3	FLAGE 2" X 150# NO EXTENSION			☐		
		4	FLAGE 2" X 300# NO EXTENSION			☐		
		5	FLAGE 3" X 150# NO EXTENSION			☐		
		6	FLAGE 3" X 300# NO EXTENSION			☐		
		7	FLAGE 2" X 150# WITH EXTENSION 150MM			☐		
		8	FLAGE 3" X 150# WITH EXTENSION 150MM			☐		
		9	FLAGE 4" X 150# NO EXTENSION			☐		
		Z	SPECIAL			☐		
TYPE OF CERTIFICATION		0	WITHOUT CERTIFICATE			☐		
		1	INTRINSIC SECURITY			☐		
		2	EXPLOSION-PROOF			☐		
CERTIFYING ENTITY		0	WITHOUT CERTIFICATE			☐		
		1	INMETRO			☐		
HOUSING MATERIAL		A	ALUMINUM			☐		
		I	INOX			☐		

		PRESSURE TRANSMITTER - ADL10					SHEET: 2 of 2	
		REVISION	BY	CHECK	APPROVED	DATE	ALTUS N°:	
							CUSTOMER	
							CUSTOMER N°:	
ELECTRICAL CONNECTION	1	1/2" - 14NPT						
COMMUNICATION CABLE	0	NO CABLE				☐		
	1	2 METERS				☐		
	2	5 METERS				☐		
	3	10 METERS				☐		
	4	20 METERS				☐		
	Z	SPECIAL				☐		
PAINTING	0	NO PAINTING				☐		
	1	BLUE - RAL 5005				☐		
	2	BLUE - PETROBRAS				☐		
SUPPORT AND FIXATION	0	WITHOUT SUPPORT				☐		
	1	STAINLESS STEEL 304				☐		
IDENTIFICATION PLATE	P0	WITH IDENTIFICATION PLATE				☐		
CALIBRATION CERTIFICATE	C0	TRACEABLE RBC				☐		
NOTES:								