
		SANITARY PRESSURE TRANSMITTER - APT10					SHEET: 1 of 2	
		REVISION	BY	CHECK	APPROVED	DATE	ALTUS N°:	
							CUSTOMER	
							CUSTOMER N°:	
DESCRIPTION		TAG NUMBER:		PIT-XXXX		MODEL:	APT10 - HS-XXXXXXXX-XX-XXXX	
OUTPUT / PROTOCOL		H	4 - 20 mA / Hart 7				OBSERVATION	
SENSOR	TYPE	S	SANITARY				THE RANGE CAN BE EXTENDED UP TO 0.8LRL AND 1.2URL WITH SMALL DEGRADATION OF ACCURACY.	
	RANGE	2	-37,4 a 37,4 kPa (-3814 a 3814 mm H2O)			<input type="checkbox"/>		
		3	-147,1 a 147,1 kPa (-1,5 a 1,5 kgf/cm²)			<input type="checkbox"/>		
		4	-690 a 690 kPa (-7 a 7 kgf/cm²)			<input type="checkbox"/>		
		5	-2068 a 2068 kPa (-21 a 21 kgf/cm²)			<input type="checkbox"/>		
DIAPHRAGM MATERIAL		I	STAINLESS STEEL 316L			<input type="checkbox"/>		
		H	HASTELLOY C276			<input type="checkbox"/>		
FILLING FLUID		S	SILICONE OIL			<input type="checkbox"/>		
		F	FLUOROLUBE			<input type="checkbox"/>		
FLANGE/ADAPTER/PURGE MATERIAL		I	STAINLESS STEEL 316					
PURGE POSITION		0	WITHOUT PURGE			<input type="checkbox"/>		
		1	OPPOSITE SIDE TO PROCESS CONNECTION			<input type="checkbox"/>		
		2	UPPER			<input type="checkbox"/>		
		3	LOW			<input type="checkbox"/>		
CELL SEALING RING		B	BUNA-N			<input type="checkbox"/>		
		V	VITON			<input type="checkbox"/>		
		T	TEFLON			<input type="checkbox"/>		
PROCESS CONECTION (REFERENCE OUTLET)		0	1/4" - 18NPT (WITHOUT ADAPTER)			<input type="checkbox"/>		
		1	1/2" - 14NPT (WITH ADAPTER)			<input type="checkbox"/>		
PROCESS CONECTION (SANITARY OUTLET)		1	TRICLAMP 1 1/2" WITHOUT EXTENSION			<input type="checkbox"/>		
		2	TRICLAMP 2" 150 WITHOUT EXTENSION			<input type="checkbox"/>		
		3	TRICLAMP 2" 150 WITH EXTENSION			<input type="checkbox"/>		
		4	SMS 1 1/2" WITHOUT EXTENSION			<input type="checkbox"/>		
		5	SMS 2" 150 WITHOUT EXTENSION			<input type="checkbox"/>		
		6	SMS 2" 150 WITH EXTENSION			<input type="checkbox"/>		
PROCESS CONECTION MATERIAL (SANITARY OUTLET)		I	STAINLESS STEEL 316					
FILLING FLUID IN THE SANITARY OUTLET		S	SILICONE DC200			<input type="checkbox"/>		
		N	GLYPOL PROPYLENE (NEOBEE)			<input type="checkbox"/>		
SANITARY OUTLET DIAPHRAGM MATERIAL		I	STAINLESS STEEL 316			<input type="checkbox"/>		
		H	HASTELLOY C276			<input type="checkbox"/>		
SANITARY OUTLET SEALING RING MATERIAL		0	WITHOUT SEALING RING			<input type="checkbox"/>		
		B	BUNA-N			<input type="checkbox"/>		
		V	VITON			<input type="checkbox"/>		
		T	TEFLON			<input type="checkbox"/>		
ADAPTATION GLOVE		0	WITHOUT GLOVE			<input type="checkbox"/>		
		1	STAINLESS STEEL 316L GLOVE			<input type="checkbox"/>		
NOTES:								

		SANITARY PRESSURE TRANSMITTER - VPT10				SHEET: 2 of 2		
						ALTUS N°: 0		
		REVISION	BY	CHECK	APPROVED	DATE	CUSTOMER 0	
							CUSTOMER N°: 0	
TYPE OF CERTIFICATION	0	WITHOUT CERTIFICATE				<input type="checkbox"/>		
	1	INTRINSIC SECURITY				<input type="checkbox"/>		
	2	EXPLOSION-PROOF				<input type="checkbox"/>		
CERTIFYING ENTITY	0	WITHOUT CERTIFICATE				<input type="checkbox"/>		
	1	INMETRO				<input type="checkbox"/>		
HOUSING MATERIAL	A	ALUMINUM				<input type="checkbox"/>		
	I	STAINLESS STEEL				<input type="checkbox"/>		
ELECTRICAL CONNECTION	1	1/2" - 14NPT						
PAINTING	0	NO PAINTING				<input type="checkbox"/>		
	1	BLUE - RAL 5005				<input type="checkbox"/>		
	2	BLUE - PETROBRAS				<input type="checkbox"/>		
IDENTIFICATION PLATE	P0	WITH IDENTIFICATION PLATE				<input type="checkbox"/>		
CALIBRATION CERTIFICATE	C0	TRACEABLE RBC				<input type="checkbox"/>		
NOTES:								

