

		PRESSURE TRANSMITTER - APT11					SHEET: 1 of 1	
		REVISION	BY	CHECK	APPROVED	DATE	ALTUS Nº:	
							CUSTOMER	
							CUSTOMER Nº:	
DESCRIPTION:		TAG NUMBER:			MODEL:		APT11 - HX-XX-XXX-XX-XXXX	
OUTPUT / PROTOCOL		H	4 - 20 mA / Hart 7				OBSERVATION	
SENSOR	PRECISION	S	STANDARD $\pm 0,075\%$			☐	AVAILABLE ONLY FOR DIFFERENTIAL AND MANOMETRIC MODELS.	
		H	HIGH PERFORMANCE $\pm 0,05\%$			☐		
	TYPE	A	ABSOLUTE			☐	THE RANGE CAN BE EXTENDED UP TO 0.8LRL AND 1.2URL WITH SMALL DEGRADATION OF ACCURACY.	
		G	GAGE			☐		
	RANGE	1	-6 a 6 kPa (-611,8 a 611,8 mm H2O)			☐		
		2	-40 a 40 kPa (-4078,9 a 4078,9 mm H2O)			☐		
		3	-100 a 250 kPa (-1 a 2,5 kgf/cm ²)			☐		
		4	-0,1 a 3 MPa (-1 a 30,6 kgf/cm ²)			☐		
5	-0,1 a 10 MPa (-1 a 102 kgf/cm ²)			☐				
6	-0,1 a 40 MPa (-1,2 a 407,9 kgf/cm ²)			☐				
DIAPHRAGM MATERIAL		I	STAINLESS STEEL 316L			☐		
		H	HASTELLOY C276			☐		
FILLING FLUID		S	SILICONE OIL			☐		
		N	NEOBEE M20			☐		
PROCESS CONECTION		0	1/2" - 14NPT FEMALE			☐		
		1	1/2" - 14NPT MALE			☐		
		2	M20 X 1,5 SEALED MALE			☐		
		3	G 1/2" MALE			☐		
		4	SANITARY DN25 DIN32676			☐		
		5	SANITARY DN40 DIN32676			☐		
		6	INTEGRAL FLANGE 2" 150#			☐		
		7	INTEGRAL FLANGE 3" 150#			☐		
		8	FLNGED REMOTE SEAL 2" 150#			☐		
		9	SANITARY DN50 DIN32676			☐		
CERTIFICATION TYPE		0	WITHOUT CERTIFICATE			☐		
		1	INTRINSIC SECURITY			☐		
		2	EXPLOSION-PROOF			☐		
CERTIFYING ENTITY		0	WITHOUT CERTIFICATE			☐		
		1	INMETRO			☐		
HOUSING MATERIAL		A	ALUMINUM			☐		
		I	STAINLESS STEEL			☐		
ELECTRICAL CONNECTION		1	1/2" - 14NPT					
PAINTING		0	NO PAINTING			☐		
		1	BLUE - RAL 5005			☐		
		2	BLUE - PETROBRAS			☐		
SUPPORT AND FIXATION		0	WITHOUT SUPPORT			☐		
		1	STAINLESS STEEL 304			☐		
IDENTIFICATION PLATE		P0	WITH IDENTIFICATION PLATE			☐		
CALIBRATION CERTIFICATE		C0	TRACEABLE RBC			☐		
NOTES:								