



# **Hadron Xtorm Series**

## **IEC 61850**

### **Profile Document**

MU223605 Rev. C

12 fevereiro de 2026

No part of this document may be copied or reproduced in any form without the prior written consent of Altus Sistemas de Automação S.A. who reserves the right to carry out alterations without prior advice.

According to current legislation in Brazil, the Consumer Defense Code, we are giving the following information to clients who use our products, regarding personal safety and premises.

The industrial automation equipment, manufactured by Altus, is strong and reliable due to the stringent quality control it is subjected to. However, any electronic industrial control equipment (programmable controllers, numerical commands, etc.) can damage machines or processes controlled by them when there are defective components and/or when a programming or installation error occurs. This can even put human lives at risk.

The user should consider the possible consequences of the defects and should provide additional external installations for safety reasons. This concern is higher when in initial commissioning and testing.

The equipment manufactured by Altus does not directly expose the environment to hazards, since they do not issue any kind of pollutant during their use. However, concerning the disposal of equipment, it is important to point out that built-in electronics may contain materials which are harmful to nature when improperly discarded. Therefore, it is recommended that whenever discarding this type of product, it should be forwarded to recycling plants, which guarantee proper waste management.

It is essential to read and understand the product documentation, such as manuals and technical characteristics before its installation or use.

The examples and figures presented in this document are solely for illustrative purposes. Due to possible upgrades and improvements that the products may present, Altus assumes no responsibility for the use of these examples and figures in real applications. They should only be used to assist user trainings and improve experience with the products and their features.

Altus warrants its equipment as described in General Conditions of Supply, attached to the commercial proposals.

Altus guarantees that their equipment works in accordance with the clear instructions contained in their manuals and/or technical characteristics, not guaranteeing the success of any particular type of application of the equipment.

Altus does not acknowledge any other guarantee, directly or implied, mainly when end customers are dealing with third-party suppliers.

The requests for additional information about the supply, equipment features and/or any other Altus services must be made in writing form. Altus is not responsible for supplying information about its equipment without formal request.

These products use EtherCAT® technology ([www.ethercat.org](http://www.ethercat.org)).

## **COPYRIGHTS**

Nexto, Ponto Series, MasterTool, Grano and WebPLC are the registered trademarks of

Altus Sistemas de Automação S.A.

*Windows, Windows NT and Windows Vista* are registered trademarks of Microsoft Corporation.

## **OPEN SOURCE SOFTWARE NOTICE**

To obtain the source code under GPL, LGPL, MPL and other open source licenses, that is contained in this product, please contact [opensource@altus.com.br](mailto:opensource@altus.com.br). In addition to the source code, all referred license terms, warranty disclaimers and copyright notices may be disclosed under request.

---

## DEVICE PROFILE REVISION HISTORY

<b>Date</b>	<b>Revision</b>	<b>Reason for change</b>	<b>Edited by</b>
11/02/2015	A	First edition.	Roque Eduardo Dapper
21/06/2016	B	Include some new Logical Nodes	Roque Eduardo Dapper
12/02/2026	C	Added PICs for IEC 61850 Client	Lucas Cecatto

# Summary

<b>1</b>	<b>MODEL IMPLEMENTATION CONFORMANCE STATEMENT .....</b>	<b>1</b>
1.1	List of Logical Nodes.....	1
<b>2</b>	<b>PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT.....</b>	<b>6</b>
2.1	ACSI Basic Conformance Statement.....	6
2.2	ACSI Models Conformance Statement .....	7
2.3	ACSI Service Conformance Statement .....	8
<b>3</b>	<b>PROTOCOL IMPLEMENTATION EXTRA INFORMATION FOR TESTING .....</b>	<b>11</b>
3.1	PIXIT for Association Model .....	11
3.2	PIXIT for Server Model .....	11
3.3	PIXIT for Dataset Model.....	12
3.4	PIXIT for Reporting Model .....	13
3.5	PIXIT for Generic Substation Events Model .....	14
3.6	PIXIT for GOOSE Performance .....	15
3.7	PIXIT for Control Model .....	16
3.8	PIXIT for Time and Time Synchronized On Model.....	18
<b>4</b>	<b>TISSUES CONFORMANCE STATEMENT .....</b>	<b>19</b>

# 1 Model Implementation Conformance Statement

This model implementation conformance statement (MICS) is applicable for the **IEC 61850 Server** driver of Hadron Xtorm Series, and specifies the modelling extensions compared to IEC 61850 edition 1. The following section contains the list of implemented logical nodes.

## 1.1 List of Logical Nodes

The following table contains the list of logical nodes implemented in the device:

<b>L: System Logical Nodes</b>
<b>LPHD</b> (Physical device information)
<b>LLN0</b> (Logical node zero)
<b>P: Logical Nodes for protection functions</b>
<b>PDIF</b> (Differential)
<b>PDIR</b> (Direction comparison)
<b>PDIS</b> (Distance)
<b>PDOP</b> (Directional overpower)
<b>PDUP</b> (Directional underpower)
<b>PFRC</b> (Rate of change of frequency)
<b>PHAR</b> (Harmonic restraint)
<b>PHIZ</b> (Ground detector)
<b>PIOC</b> (Instantaneous overcurrent)
<b>PMRI</b> (Motor restart inhibition)
<b>PMSS</b> (Motor starting time supervision)
<b>POPF</b> (Over power factor)
<b>PPAM</b> (Phase angle measuring)
<b>PSCH</b> (Protection scheme)
<b>PSDE</b> (Sensitive directional earthfault)
<b>PTEF</b> (Transient earth fault)
<b>PTOC</b> (Time overcurrent)
<b>PTOF</b> (Overfrequency)
<b>PTOV</b> (Overvoltage)
<b>PTRC</b> (Protection trip conditioning)
<b>PTTR</b> (Thermal overload)

<b>PTUC</b> (Undercurrent)
<b>PTUF</b> (Underfrequency)
<b>PTUV</b> (Undervoltage)
<b>PUPF</b> (Underpower factor)
<b>PVOC</b> (Voltage controlled time overcurrent)
<b>PVPH</b> (Volts per Hz)
<b>PZSU</b> (Zero speed or underspeed)
<b>R: Logical nodes for protection related functions</b>
<b>RBRF</b> (Breaker failure)
<b>RDIR</b> (Directional element)
<b>RDRE</b> (Disturbance recorder function)
<b>RDRS</b> (Disturbance record handling)
<b>RFLO</b> (Fault locator)
<b>RPSB</b> (Power swing detection/blocking)
<b>RREC</b> (Autoreclosing)
<b>RSYN</b> (Synchronism-check or synchronising)
<b>C: Logical Nodes for control</b>
<b>CALH</b> (Alarm handling)
<b>CCGR</b> (Cooling group control)
<b>CILO</b> (Interlocking)
<b>CPOW</b> (Point-on-wave switching)
<b>CSWI</b> (Switch controller)
<b>G: Logical Nodes for generic references</b>
<b>GAPC</b> (Generic automatic process control)
<b>GGIO</b> (Generic process I/O)
<b>GSAL</b> (Generic security application)
<b>I: Logical Nodes for interfacing and archiving</b>
<b>IARC</b> (Archiving)
<b>IHMI</b> (Human machine interface)
<b>ITCI</b> (Telecontrol interface)
<b>ITMI</b> (Telemonitoring interface)
<b>A: Logical Nodes for automatic control</b>

## 1. Model Implementation Conformance Statement

<b>ANCR</b> (Neutral current regulator)
<b>ARCO</b> (Reactive power control)
<b>ATCC</b> (Automatic tap changer controller)
<b>AVCO</b> (Voltage control)
<b>M: Logical Nodes for metering and measurement</b>
<b>MDIF</b> (Differential measurements)
<b>MMTR</b> (Metering)
<b>MMXN</b> (Non phase related Measurement)
<b>MMXU</b> (Measurement)
<b>MSQI</b> (Sequence and imbalance)
<b>MSTA</b> (Metering Statistics)
<b>S: Logical Nodes for sensors and monitoring</b>
<b>SARC</b> (Monitoring and diagnostics for arcs)
<b>SIMG</b> (Insulation medium supervision (gas))
<b>SIML</b> (Insulation medium supervision (liquid))
<b>SLTC</b> (Tap changer supervision)
<b>SPDC</b> (Monitoring and diagnostics for partial discharges)
<b>SPTR</b> (Power transformer supervision)
<b>X: Logical Nodes for switchgear</b>
<b>XCBR</b> (Circuit breaker)
<b>XSWI</b> (Switch)
<b>T: Logical Nodes for instrument transformers</b>
<b>TCTR</b> (Current transformer)
<b>TVTR</b> (Voltage transformer)
<b>TPRS</b> (Pressure sensor)
<b>Y: Logical Nodes for power transformers</b>
<b>YEFN</b> (Earth fault neutralizer (Petersen coil))
<b>YLTC</b> (Tap changer)
<b>YPSH</b> (Power shunt)
<b>YPTR</b> (Power transformer)
<b>Z: Logical Nodes for further power system equipment</b>
<b>ZAXN</b> (Auxiliary network)

ZBAT (Battery)
ZBSH (Bushing)
ZCAB (Power cable)
ZCAP (Capacitor bank)
ZCON (Converter)
ZGEN (Generator)
ZGIL (Gas insulated line)
ZLIN (Power overhead line)
ZMOT (Motor)
ZREA (Reactor)
ZRRC (Rotating reactive component)
ZSAR (Surge arrester)
ZTCF (Thyristor controlled frequency converter)
ZTCR (Thyristor controlled reactive component)
<b>K: Logical Nodes for further power system equipment</b>
KFAN (Fan)
KFIL (Filter)
KPMP (Pump)
KVLV (Valve control)
<b>F: Logical nodes for functional blocks</b>
FXOT (Action at over threshold Name)
FXUT (Action at under threshold Name)
<b>H: Hydropower specific logical nodes</b>
HBRG (Turbine – generator shaft bearing)
HCON (Combinator)
HDAM (Hydropower dam)
HDLS (Dam leakage supervision)
HGPI (Gate position indicator)
HGTE (Dam Gate)
HITG (Intake Gate)
HJCL (Power plant joint control function)
HLKG (Leakage supervision)

---

## 1. Model Implementation Conformance Statement

<b>HLVL</b> (Dam water level indicator)
<b>HMBR</b> (Mechanical brake for the generator shaft)
<b>HNDL</b> (Needle control)
<b>HNHD</b> (Net head data)
<b>HOTP</b> (Dam overtopping protection)
<b>HRES</b> (Water reservoir)
<b>HSEQ</b> (Start/stop sequencer)
<b>HSPD</b> (Speed monitoring)
<b>HUNT</b> (Hydropower production unit)
<b>HWCL</b> (Water control function)

## 2 Protocol Implementation Conformance Statement

This protocol implementation conformance statement (PICS) is used to provide an overview and details about the **IEC 61850 Server** and **MMS Client** driver of Hadron Xtorm Series, and it is composed by the following ACSI conformance statements:

- ASCI basic conformance statement
- ACSI models conformance statement
- ACSI service conformance statement

These statements specify the communication features mapped to IEC 61850-8-1.

### 2.1 ASCI Basic Conformance Statement

The basic conformance statement is defined in Table A.1.

**Table A.1 – Basic conformance statement**

		Client/ Subscriber	Server/ Publisher	Value/ Comments
<b>Client-Server roles</b>				
B11	<b>Server</b> side (of TWO-PARTY-APPLICATION-ASSOCIATION)	—	Y	
B12	<b>Client</b> side of (TWO-PARTY-APPLICATION-ASSOCIATION)	Y	—	
<b>SCSMs supported</b>				
B21	<b>SCSM</b> : IEC 6185-8-1 used	Y	Y	
B22	<b>SCSM</b> : IEC 6185-9-1 used			Deprecated Ed2
B23	<b>SCSM</b> : IEC 6185-9-2 used			
B24	<b>SCSM</b> : other			
<b>Generic substation event model (GSE)</b>				
B31	<b>Publisher</b> side	—	Y	
B32	<b>Subscriber</b> side		—	
<b>Transmission of sampled value model (SVC)</b>				
B41	<b>Publisher</b> side	—		
B42	<b>Subscriber</b> side		—	
— Y = supported N or empty = not supported				

## 2.2 ACSI Models Conformance Statement

The ACSI models conformance statement is defined in Table A.2.

**Table A.2 – ACSI models conformance statement**

		Client/ Subscriber	Server/ Publisher	Value/Comments
If <b>Server or Client</b> side (B11/12) supported				
M1	<b>Logical device</b>	Y	Y	
M2	<b>Logical node</b>	Y	Y	
M3	<b>Data</b>	Y	Y	
M4	<b>Data set</b>	Y	Y	
M5	<b>Substitution</b>	Y		
M6	<b>Setting group control</b>	Y		
	<b>Reporting</b>			
M7	<b>Buffered report control</b>	Y	Y	
M7-1	sequence-number	Y	Y	
M7-2	report-time-stamp	Y	Y	
M7-3	reason-for-inclusion	Y	Y	
M7-4	data-set-name	Y	Y	
M7-5	data-reference	Y	Y	
M7-6	buffer-overflow	Y	Y	
M7-7	entryID	Y	Y	
M7-8	BufTm	Y	Y	
M7-9	IntgPd	Y	Y	
M7-10	GI	Y	Y	
M7-11	Conf-revision	Y		
M8	<b>Unbuffered report control</b>	Y	Y	
M8-1	sequence-number	Y	Y	
M8-2	report-time-stamp	Y	Y	
M8-3	reason-for-inclusion	Y	Y	
M8-4	data-set-name	Y	Y	
M8-5	data-reference	Y	Y	
M8-6	BufTm	Y	Y	
M8-7	IntgPd	Y	Y	
M8-8	GI	Y	Y	
	<b>Logging</b>			
M9	<b>Log control</b>			
M9-1	IntgPd			
M10	<b>Log</b>			
M11	<b>Control</b>	Y	Y	
M17	<b>File Transfer</b>			
M18	<b>Application Association</b>			
M19	<b>GOOSE Control Block</b>			
M20	<b>Sampled Value Control Block</b>			
If <b>GSE</b> (B31/32) is supported				
M12	<b>GOOSE</b>	Y		

## 2. Protocol Implementation Conformance Statement

		Client/ Subscriber	Server/ Publisher	Value/Comments
M13	<b>GSSE</b>			Deprecated Ed2
If <b>SVC</b> (41/42) is supported				
M14	Multicast SVC			
M15	Unicast SVC			
If <b>Server or Client</b> side (B11/12) supported				
M16	<b>Time</b>	Y	Y	
M17	<b>File Transfer</b>			
Y = service is supported				
N or empty = service is not supported				

### 2.3 ACSI Service Conformance Statement

The ACSI service conformance statement is defined in Table A.3 (depending on the statements in Table A.1).

**Table A.3 – ACSI service Conformance statement**

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
<b>Server</b>					
S1	GetServerDirectory	TP	Y	Y	Client = Ed2   Server = Ed1
<b>Application association</b>					
S21	Associate Request		Y	Y	Client = Ed2   Server = Ed1
S22	Associate Response		Y	Y	Client = Ed2   Server = Ed1
S31	Abort Request		Y	Y	Client = Ed2   Server = Ed1
S32	Abort Response		Y	Y	Client = Ed2   Server = Ed1
S41	Release Request		Y	Y	Client = Ed2   Server = Ed1
S42	Release Response		Y	Y	Client = Ed2   Server = Ed1
<b>Logical device</b>					
S5	GetLogicalDeviceDirectory	TP	Y	Y	Client = Ed2   Server = Ed1
<b>Logical node</b>					
S6	GetLogicalNodeDirectory	TP	Y	Y	Client = Ed2   Server = Ed1
S7	GetAllDataValues	TP	Y	Y	Client = Ed2   Server = Ed1
<b>Data</b>					
S8	GetDataValues	TP	Y	Y	Client = Ed2   Server = Ed1
S9	SetDataValues	TP	Y		Client = Ed2   Server = Ed1
S10	GetDataDirectory	TP	Y	Y	Client = Ed2   Server = Ed1
S11	GetDataDefinition	TP	Y	Y	Client = Ed2   Server = Ed1
<b>Data set</b>					
S12	GetDataSetValues	TP	Y	Y	Client = Ed2   Server = Ed1
S13	SetDataSetValues	TP			Client = Ed2   Server = Ed1
S14	CreateDataSet	TP		Y	Client = Ed2   Server = Ed1
S15	DeleteDataSet	TP		Y	Client = Ed2   Server = Ed1
S16	GetDataSetDirectory	TP	Y	Y	Client = Ed2   Server = Ed1

## 2. Protocol Implementation Conformance Statement

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
<b>Substitution</b>					
S17	SetDataValues	TP	Y		Client = Ed2   Server = Ed1
<b>Setting group control</b>					
S18	SelectActiveSG	TP			Client = Ed2   Server = Ed1
S19	SelectEditSG	TP			Client = Ed2   Server = Ed1
S20	SetSGValues	TP			Client = Ed2   Server = Ed1
S21	ConfirmEditSGValues	TP			Client = Ed2   Server = Ed1
S22	GetSGValues	TP			Client = Ed2   Server = Ed1
S23	GetSGCBValues	TP			Client = Ed2   Server = Ed1
<b>Reporting</b>					
Buffered report control block (BRCB)					
S24	Report	TP	Y	Y	Client = Ed2   Server = Ed1
S24-1	data-change (dchg)		Y	Y	Client = Ed2   Server = Ed1
S24-2	quality-change (qchg)		Y	Y	Client = Ed2   Server = Ed1
S24-3	data-update (dupd)		Y	Y	Client = Ed2   Server = Ed1
S25	GetBRCBValues	TP		Y	Client = Ed2   Server = Ed1
S26	SetBRCBValues	TP		Y	Client = Ed2   Server = Ed1
Unbuffered report control block (URCB)					
S27	Report	TP	Y	Y	Client = Ed2   Server = Ed1
S27-1	data-change (dchg)		Y	Y	Client = Ed2   Server = Ed1
S27-2	quality-change (qchg)		Y	Y	Client = Ed2   Server = Ed1
S27-3	data-update (dupd)		Y	Y	Client = Ed2   Server = Ed1
S28	GetURCBValues	TP		Y	Client = Ed2   Server = Ed1
S29	SetURCBValues	TP		Y	Client = Ed2   Server = Ed1
<b>Logging</b>					
Log control block					
S30	GetLCBValues	TP			Client = Ed2   Server = Ed1
S31	SetLCBValues	TP			Client = Ed2   Server = Ed1
Log					
S32	QueryLogByTime	TP			Client = Ed2   Server = Ed1
S33	QueryLogAfter	TP			Client = Ed2   Server = Ed1
S34	GetLogStatusValues	TP			Client = Ed2   Server = Ed1
<b>Generic substation event model (GSE)</b>					
GOOSE-CONTROL-BLOCK					
S35	SendGOOSEMessage	MC			Client = Ed2   Server = Ed1
S36	GetGoReference	TP			Client = Ed2   Server = Ed1
S37	GetGOOSEElementNumber	TP			Client = Ed2   Server = Ed1
S38	GetGoCBValues	TP			Client = Ed2   Server = Ed1
S39	SetGoCBValues	TP			Client = Ed2   Server = Ed1
GSSE-CONTROL-BLOCK					
S40	SendGSSEMessage	MC			Deprecated in Edition 2
S41	GetGsReference	TP			Deprecated in Edition 2
S42	GetGSSEDataOffset	TP			Deprecated in Edition 2
S43	GetGsCBValues	TP			Deprecated in Edition 2
S44	SetGsCBValues	TP	Y/N		Deprecated in Edition 2
<b>Transmission of sampled value model (SVC)</b>					
Multicast SVC					
S45	SendMSVMessage	MC			Client = Ed2   Server = Ed1

## 2. Protocol Implementation Conformance Statement

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
S46	GetMSVCBValues	TP			Client = Ed2   Server = Ed1
S47	SetMSVCBValues	TP			Client = Ed2   Server = Ed1
S62	GetMsvReference	TP			Client = Ed2   Server = Ed1
S63	GetMSVElementNumber	TP			Client = Ed2   Server = Ed1
<b>Unicast SVC</b>					
S48	SendUSVMessage	TP			Client = Ed2   Server = Ed1
S49	GetUSVCBValues	TP			Client = Ed2   Server = Ed1
S50	SetUSVCBValues	TP			Client = Ed2   Server = Ed1
<b>Control</b>					
S51	Select		Y	Y	Client = Ed2   Server = Ed1
S52	SelectWithValue	TP	Y	Y	Client = Ed2   Server = Ed1
S53	Cancel	TP	Y		Client = Ed2   Server = Ed1
S54	Operate	TP	Y	Y	Client = Ed2   Server = Ed1
S55	CommandTermination	TP	Y		Client = Ed2   Server = Ed1
S56	TimeActivatedOperate	TP			Client = Ed2   Server = Ed1
<b>File transfer</b>					
S57	GetFile	TP			Client = Ed2   Server = Ed1
S58	SetFile	TP			Client = Ed2   Server = Ed1
S59	DeleteFile	TP			Client = Ed2   Server = Ed1
S60	GetFileAttributeValues	TP			Client = Ed2   Server = Ed1
S61	GetServerDirectory (FILE-SYSTEM)	TP			Client = Ed2   Server = Ed1
<b>Time</b>					
T1	Time resolution of internal clock		20	20	nearest negative power of 2 in seconds
T2	Time accuracy of internal clock		T1	T1	TL (ms) (low accuracy), T3 < 7) (only Ed2) T0 (ms) (<= 10 ms), 7 <= T3 < 9 T1 (µs) (<= 1 ms), 10 <= T3 < 13 T2 (µs) (<= 100 µS), 13 <= T3 < 15 T3 (µs) (<= 25 µS), 15 <= T3 < 18 T4 (µs) (<= 25 µS), 15 <= T3 < 18 T5 (µs) (<= 1 µS), T3 >= 20
T3	Supported TimeStamp resolution		20	20	nearest negative power of 2 in seconds
Y = service is supported					
N or empty = service is not supported					

## 3 Protocol Implementation Extra Information for Testing

This chapter specifies the protocol implementation extra information for testing (PIXIT) for the **IEC 61850 Server** driver of Hadron Xtorm Series. Together with the PICS and the MICS, the PIXIT forms the basis for a conformance test according to IEC 61850-10.

The following sections specify the PIXIT for each applicable ACSI service model as structured in IEC 61850-10.

### 3.1 PIXIT for Association Model

ID	Description	Value / Clarification
As1	Maximum number of clients that can set-up an association simultaneously	5
As2	TCP_KEEPALIVE value	20 seconds
As3	Lost connection detection time	60 seconds
As4	Is authentication supported	N
As5	What association parameters are necessary for successful association	Transport selector Y Session selector Y Presentation selector Y AP Title N AE Qualifier N
As6	If association parameters are necessary for association, describe the correct values e.g.	Transport selector 0001 Session selector 0001 Presentation selector 00000001
As7	What is the maximum MMS PDU size	65000
As8	What is the maximum start up time after a power supply interrupt	25 seconds

### 3.2 PIXIT for Server Model

ID	Description	Value / Clarification
Sr1	Which analogue value (MX) quality bits are supported (can be set by server)	Validity: Y Good, Y Invalid, Y Reserved, Y Questionable Y Overflow Y OutofRange Y BadReference Y Oscillatory Y Failure YOldData

### 3. Protocol Implementation Extra Information for Testing

ID	Description	Value / Clarification
		Y Inconsistent Y Inaccurate Source: Y Process Y Substituted Y Test Y OperatorBlocked
Sr2	Which status value (ST) quality bits are supported (can be set by server)	Validity: Y Good, Y Invalid, Y Reserved, Y Questionable Y BadReference Y Oscillatory Y Failure Y OldData Y Inconsistent Y Inaccurate Source: Y Process Y Substituted Y Test Y OperatorBlocked
Sr3	What is the maximum number of data values in one GetDataValues request	1000
Sr4	What is the maximum number of data values in one SetDataValues request	1000
Sr5	Which Mode / Behaviour values are supported	On Y Blocked Y Test Y Test/Blocked Y Off Y

### 3.3 PIXIT for Dataset Model

ID	Description	Value / Clarification
Ds1	What is the maximum number of data elements in one data set (compare ICD setting)	No fixed limit, it depends on the available memory.
Ds2	How many persistent data sets can be created by one or more clients	100
Ds3	How many non-persistent data sets can be created by one or more clients	10

## 3.4 PIXIT for Reporting Model

ID	Description	Value / Clarification
Rp1	The supported trigger conditions are (compare PICS)	integrity Y data change Y quality change Y data update N general interrogation Y
Rp2	The supported optional fields are	sequence-number Y report-time-stamp Y reason-for-inclusion Y data-set-name Y data-reference Y buffer-overflow Y entryID Y conf-rev Y segmentation N
Rp3	Can the server send segmented reports	N
Rp4	Mechanism on second internal data change notification of the same analogue data value within buffer period (Compare IEC 61850-7-2 §14.2.2.9)	Send report immediately
Rp5	Multi client URCB approach (compare IEC 61850-7-2 §14.2.1)	Each URCB is visible to one client only
Rp6	What is the format of EntryID	Octect64
Rp7	What is the buffer size for each BRCB or how many reports can be buffered	20000 bytes
Rp8	Pre-configured RCB attributes that cannot be changed online when RptEna = FALSE (see also the ICD report settings)	-
Rp9	May the reported data set contain: - structured data objects? - data attributes?	Y Y
Rp10	What is the scan cycle for binary events? Is this fixed, configurable	Fixed 120 uS (IO Module detecting events, eg HX1120 )  Configurable 5 – 100 mS ( if detecting events in the scan cycle )
Rp11	Does the device support to pre-assign a RCB to a specific client in the SCL	N

## 3.5 PIXIT for Generic Substation Events Model

ID	Description	Value / Clarification	
Go1	What elements of a subscribed GOOSE header are checked to decide the message is valid and the allData values are accepted? If yes, describe the conditions. Note: the VLAN tag may be removed by a ethernet switch and should not be checked	Y	source MAC address
		N	destination MAC address
		Y	Ethertype = 0x88B8
		Y	APPID
		Y	gocbRef
		N	timeAllowedtoLive
		N	datSet
		Y	gold
		N	t
		N	stNum
		N	sqNum
		N	test
		N	confRev
		N	ndsCom
		Y	numDatSetEntries
Go2	Can the test flag in the published GOOSE be turned on / off	N	
Go3	Does the DUT accept a configuration with a GOOSE control block with empty data set or too large data set?	No, the GoCB need to be removed from the configuration	
Go4	What is the behaviour when the GOOSE publish configuration is incorrect	DUT will send GOOSE with NdsCom=T	
Go5	When is a subscribed GOOSE marked as lost? (TAL = time allowed to live value from the last received GOOSE message)	a) message does not arrive prior to TAL	
Go6	What is the behaviour when one or more subscribed GOOSE messages isn't received or syntactically incorrect (missing GOOSE)	If GOOSE message is not received, timeout diagnostic is set and memory is kept with last value. If message is received incorrect, receive error diagnostic is set and memory is not updated and last value is kept.	
Go7	What is the behaviour when a subscribed GOOSE message is out-of-order	Memory is not updated and last value is kept.	
Go8	What is the behaviour when a subscribed GOOSE message is duplicated	Memory is not updated and last value is kept.	
Go9	Does the device subscribe to GOOSE messages with/without the VLAN tag?	Y with the VLAN tag	
Go10	May the GOOSE data set contain: - structured data objects (FCD)? - timestamp data attributes? Note: data attributes (FCDA) is mandatory	Subscribed	Published
		Y	Y
		Y	Y

### 3. Protocol Implementation Extra Information for Testing

ID	Description	Value / Clarification
Go11	Published FCD supported common data classes / data types are	ACD BSC CMV CURVE DPC DPS SEQ MV CMV WYE
Go12	Subscribed FCD supported common data classes / data types are	ACD BSC CMV CURVE DPC DPS SEQ MV CMV WYE
Go13	What is the slow retransmission time? Is it fixed or configurable?	4294967295 ms with TAL = 4294967295 ms Configured by proprietary IED Configurator.
Go14	What is the minimum supported retransmission time? What is the maximum supported retransmission time?  Is it fixed or configurable?	1 ms  4294967295 ms  Configurable
Go15	Can the GOOSE publish be turned on / off by using SetGoCBValues(GoEna)	Y

TAL = Time Allowed to Live

### 3.6 PIXIT for GOOSE Performance

ID	Description	Value / Clarification	
Gp1	Performance class	P2/P3	
Gp2	GOOSE ping-pong processing method	Scan cycle based	
Gp3	Application logic scan cycle(ms)	Max.	100 ms (MainTask)
		Min.	1 ms (ProtTask)
Gp4	Maximum number of data attributes in GOOSE dataset (value and quality has to be counted as separate attributes)	300	
Gp5	Maximum number of GOOSE to be published	100	

ID	Description	Value / Clarification
Gp6	Maximum number of GOOSE to be subscribed	100
Gp7	Data types in GOOSE dataset for published GOOSEs According to 7-2 Table 2	BOOLEAN INT8 INT16 INT24 INT32 INT128 INT8U INT16U INT24U INT32U FLOAT32 FLOAT64 ENUMERATED CODED ENUM OCTET STRING VISIBLE STRING UNICODE STRING
Gp8	Data types in GOOSE dataset for subscribed GOOSEs According to 7-2 Table 2	BOOLEAN INT8 INT16 INT24 INT32 INT128 INT8U INT16U INT24U INT32U FLOAT32 FLOAT64 ENUMERATED CODED ENUM OCTET STRING VISIBLE STRING UNICODE STRING

### 3.7 PIXIT for Control Model

ID	Description	Value / Clarification
Ct1	What control models are supported (compare PICS)	Y status-only Y direct-with-normal-security Y sbo-with-normal-security N direct-with-enhanced-security N sbo-with-enhanced-security

### 3. Protocol Implementation Extra Information for Testing

ID	Description	Value / Clarification
Ct2	Is the control model fixed, configurable and/or online changeable?	Online changeable
Ct3	Is TimeActivatedOperate supported	N
Ct4	Is "operate-many" supported	N
Ct5	Will the DUT activate the control output when the test attribute is set in the SelectWithValue and/or Operate request (when N test procedure Ctl2 is applicable)	N ( if blocked by the user )
Ct6	What are the conditions for the time (T) attribute in the SelectWithValue and/or Operate request	DUT ignores the time value and execute the command as usual
Ct7	Is pulse configuration supported	Y
Ct8	What is the synchron of the DUT when the check conditions are set  Is this synchron fixed, configurable, online changeable?	N synchrocheck N interlock-check  Fixed
Ct9	What additional cause diagnosis are supported	NA
Ct10	How to force a "test-not-ok" respond with SelectWithValue request?	NA
Ct11	How to force a "test-not-ok" respond with Select request?	Select a data object which is selected by another client.
Ct12	How to force a "test-not-ok" respond with Operate request?	Operate a data object which is selected by another client.
Ct13	Which origin categories are supported?	All
Ct14	What happens if the orCat value is not supported?	All originator categories are supported by default.
Ct15	Does the IED accept a SelectWithValue/Operate with the same ctlVal as the current status value?	Dons: N SBOs: N Does: NA SBOes: NA
Ct16	Does the IED accept a select/operate on the same control object from 2 different clients at the same time?	Dons: N SBOs: N Does: N SBOes: N
Ct17	Does the IED accept a Select/SelectWithValue from the same client when the control object is already selected (tissue 334)	SBOs: Y SBOes: NA
Ct18	Is for SBOes the internal validation performed during the SelectWithValue and/or Operate step?	NA
Ct19	Can a control operation be blocked by Mod=Off or Blocked	Y
Ct20	Does the IED support local / remote operation?	Y
Ct21	Does the IED send an InformationReport with LastApplError as part of the Operate response- for control with normal security?	NA

### 3.8 PIXIT for Time and Time Synchronized On Model

ID	Description	Value / Clarification
Tm1	What quality bits are supported (may be set by the IED)	Y LeapSecondsKnown N ClockFailure Y ClockNotSynchronized
Tm2	Describe the synchron when the time synchronization signal/messages are lost	The IED sets ClockNotSynchronized
Tm3	When is the time quality bit "ClockFailure" set?	NA
Tm4	When is the time quality bit "Clock not 18synchronized" set?	The IED sets ClockNotSynchronized when there is a loss of SNTP or IRIG time synchronization
Tm5	Is the timestamp of a binary event adjusted to the configured scan cycle?	Y
Tm6	Does the device support time zone and daylight saving?	Y
Tm7	Which attributes of the SNTP response packet are validated?	Y Leap indicator not equal to 3? Y Mode is equal to SERVER Y OriginateTimestamp is equal to value sent by the SNTP client as Transmit Timestamp N RX/TX timestamp fields are checked for reasonableness Y SNTP version 3 and/or 4

## 4 Tissues Conformance Statement

This Tissues conformance statement (TICS) is applicable for the **IEC 61850 Server** driver of Hadron Xtorm Series, and describes the Technical Issues that were implemented on this product.

During the October 2006 meeting IEC TC57 working group 10 decided that:

- Green Tissues with the category “IntOp” are mandatory for IEC 61850 edition 1
- Tissues with the category “Ed.2” Tissues should not be implemented.

Below table gives an overview of the IntOp Tissues and testing status.

Tissues 45, 46, 49, 190 and 278 are not mandatory, all other tissues in the table are mandatory if applicable.

Part 8-1	<b>116</b>	GetNameList with empty response?	IntOp	Yes
	<b>165</b>	Improper Error Response for GetDataSetValues	IntOp	Yes
	<b>183</b>	GetNameList error handling	IntOp	Yes
	<b>235</b>	Extension of Name length	IntOp	Yes
Part 7-4	None			
Part 7-3	<b>28</b>	Definition of APC	IntOp	Yes
	<b>54</b>	Point def xVal, not cVal	IntOp	Yes
	<b>55</b>	Ineut = Ires ?	IntOp	Appl
	<b>60</b>	Services missing in tables	IntOp	Yes
	<b>63</b>	mag in CDC CMV	IntOp	Appl
	<b>65</b>	Deadband calculation of a Vector and trigger option	IntOp	Appl
	<b>219</b>	operTm in ACT	IntOp	Yes
Part 7-2	<b>270</b>	WYE and DEL rms values	IntOp	Appl
	<b>30</b>	control parameter T	IntOp	Yes
	<b>31</b>	Typo	IntOp	Appl
	<b>32</b>	Typo in syntax	IntOp	Yes
	<b>35</b>	Typo Syntax Control time	IntOp	Yes
	<b>36</b>	Syntax parameter DSet-Ref missing	IntOp	Yes
	<b>37</b>	Syntax GOOSE "T" type	IntOp	Yes
	<b>38</b>	Syntax "AppID" or "GoID"	IntOp	Yes
	<b>39</b>	Add DstAddr to GoCB	IntOp	Yes
	<b>40</b>	GOOSE Message "AppID" to "GoID"	IntOp	Yes
	<b>41</b>	GsCB "AppID" to "GsID"	IntOp	Yes
	<b>42</b>	SV timestamp: "EntryTime" to "TimeStamp"	IntOp	Yes
	<b>43</b>	Control "T" semantic	IntOp	Yes
	<b>44</b>	AddCause - Object not sel	IntOp	Yes
	<b>45(*)</b>	Missing AddCauses	IntOp(*)	Yes
	<b>46(*)</b>	Synchro check cancel	IntOp(*)	Appl
	<b>47</b>	"," in LD Name?	IntOp	Yes
	<b>49(*)</b>	BRCB TimeOfEntry?	IntOp(*)	Yes
	<b>50</b>	LNNName start with number?	IntOp	Yes
	<b>51</b>	ARRAY [0..num] missing	IntOp	Yes
	<b>52**</b>	Ambiguity GOOSE SqNum	IntOp	Yes
	<b>53</b>	Add DstAddr to GsCB, SV	IntOp	Yes
	<b>151</b>	Name constraint for control blocks etc.	IntOp	Yes
	<b>166</b>	DataRef attribute in Log	IntOp	Yes
	<b>185</b>	Logging - Integrity periode	IntOp	Yes
	<b>189</b>	SV Format	IntOp	N/A
	<b>190(*)</b>	BRCB: EntryId and TimeOfEntry	IntOp(*)	Yes
	<b>191**</b>	BRCB: Integrity and buffering reports	IntOp	Yes
	<b>234**</b>	New type CtxInt	IntOp	Ed2
	<b>275**</b>	Confusing statement on GI usage	IntOp	Yes
<b>278(*)</b>	EntryId not valid for a server	IntOp(*)	Yes	
Part 6	<b>1</b>	Syntax	IntOp	Yes
	<b>5</b>	tExtensionAttributeNameEnum is restricted	IntOp	Yes

<b>8</b>	SIUnit enumeration for W	IntOp	Yes
<b>10</b>	Base type for bitstring usage	IntOp	Yes
<b>17</b>	DAI/SDI elements syntax	IntOp	Yes
<b>169</b>	Ordering of enum differs from 7-3	IntOp	Yes

(\*) = Tissue is not clarified in enough detail for testing

\*\* = Tissue status is not green, but is clarified in enough detail for testing

Implementation notes:

Yes – implemented in the library

Appl – must be implemented in application (user) code

N/A – doesn't apply (Sampled values not implemented)

Ed2 – adds classes that are new in Edition 2